

# CADWELD WELDED ELECTRICAL CONNECTIONS METRIC



# CADWELD PLUS

The Standard by which all others are measured




**CADWELD PLUS** is a revolutionary system that simplifies the process for exothermically welded connections.

**Reliable** – CADWELD connections consistently perform the best in independent IEEE® 837 tests.

**Innovative** – CADWELD PLUS offers easy ignition and increases flexibility in hard-to-reach areas.

**Easy to Use** – CADWELD PLUS connections require fewer parts, no starting material and no cumbersome tools.

**Most Experienced** – Pentair, the recognized leader in grounding and bonding.



CADWELD PLUS is the ultimate exothermic welded connection



Space-saving packaging ships and stores easily

IEEE is a registered trademark of The Institute of Electrical and Electronics Engineers, Incorporated

# Table of Contents

Ordering Information	1	Ground Rod Splice – GB	31
The CADWELD Mould Numbering System	2-3	Cable to Rebar – RR	32
Metric to Imperial Conversion Chart	4	Cable to Rebar – RD	33
CADWELD – Technical Advantages	5-6	Cable/Busbar Tape to Rebar – RJ	34
Technical Information	7	CADWELD Cast Ground Plates	35
CADWELD PLUS	8	Aircraft Grounding Receptacles	36
CADWELD MULTI	9-10	Other Cable to Cable Connections	37
Horizontal Connection – SS	11	Other Cable to Ground Rods or Other Connections	38
Horizontal Tee – TA	12	Other Cable to Steel or Cast Iron Connections	39
Horizontal X – XA/XB	13	Other Cable to Busbar or Lug Connections	40
Parallel Horizontal – PT	14	Other Busbar to Busbar Connections	41
Horizontal Steel Surface – HA/HS	15	Other Busbar Connections	42
Vertical Steel Surface – VS	16	Other Rebar Connections	42
Studs – HX/HV	17	Cable to Copper Tube Connections	43
Busbar Tape – BA/BB	18	Busbar to Ground Rods Connections	43
Busbar Tape – BM/BQ	19	Copper Tube to Ground Rods Connections	44
Cable to Busbar Tape – LE	20	Copper Tube to Copper Tube Connections	44
Busbar Tape – EB	21	Copper Tube to Busbar or Lugs Connections	44
Busbar Tape – BW/CG	22		
Cable to Busbar Tape – LJ	23	<b>Material, Tools and Accessories</b>	
Copper Lugs – LA	24	Adapting Moulds to Fit Conductors	45
Copper Lugs – GL	25	Cable and Work Surface Preparation	46
Cable to Ground Rod – GR	26	Mould Care and Use	47
Cable to Ground Rod – GT	27	Mould Fastening and Mounting	48-49
Cable/Tape to Ground Rod – GY/LQ	28	Ground Rod Specialty Tools	50
Tape to Ground Rod – CP/CN	29	Other Tools	50-51
Cable to Ground Rod		Tool Kits / Tool Tray	51
CADWELD ONE SHOT – GR/GT	30	Reference Material	52

## How to Order CADWELD Products

This catalog lists popular CADWELD connections. Look in the index for the connection you need. If you cannot find the connection you need, contact Pentair or your local distributor or agent. Only the most popular CADWELD connections are listed in this catalog. We have designed over 45,000 connections and “specials” are designed every day.

### 1. What connection do you require?

Available connections are listed in the pictorial index which also shows the degree of difficulty in making the connection, and ease of mould cleaning. We strongly recommend that wherever possible you use moulds listed in this catalog. After selecting the connection, turn to the appropriate page and select the mould, welding material and tools you need.

### 2. What are the conductor sizes?

This catalog covers connections between solid or concentric stranded copper conductors, and busbars to each other, to lugs, to ground rods, to rebar, to rail and to special grounding accessories. For sizes not listed, contact your local CADWELD distributor, agent, or Pentair.


**Note:** Other publications describe connections to conductors of copperclad, high voltage copper, aluminium, busbar, lightning protection cable, steel cable, etc.

### 3. You must have the following to make a weld:


1. Mould to fit your conductors.
2. Welding material required by your mould.
3. Handle clamps or frame.
4. CADWELD PLUS Control Unit or Flint Ignitor.
5. Lugs, sleeves, packing material listed on the page with the mould.

# The CADWELD Mould Numbering System

The CADWELD Mould Part Number gives, in code, the complete information of the mould – type of connection, mould price key, and conductor size(s).



## EXAMPLES



### Certain tools may be required for various connections.

If required, these tools are listed on the same page as the connection and in Section A.

- Some tools listed in Section A can save you a lot of time.
- Also refer to A9E, Contractor Tips, to make your job easier, and learn about labor saving ideas.

For other CADWELD literature, videos and software, See Page 50.

For all your connection needs – we're only a phone call away. See back cover for a complete listing of Pentair offices or call your local CADWELD distributor or agent.

## REQUIRED TOOLS SUMMARY

Required tools are listed with each mould. For your reference, handle clamps and/or frame are summarized below.

<u>MOULD</u>	<u>REQUIRED</u>
A*	Includes frame with handle
C, Q & R	Requires L160
D, F & Z	Requires L159
E*	Includes frame but also requires L160
J*	Includes frame but also requires L159
K*, M* & V*	Includes frame with handles

\* To order mould only - without handles or frame - add suffix "M" to mould part number.

# The CADWELD Mould Numbering System

## COMMON REFERENCE FOR CABLE DIAMETERS

Nominal Area (mm <sup>2</sup> )	Concentric Cable		
	Strand	Diameter Range (mm)	Cable Size Code
6	7/1.07	3,21	A7
10	7/1.37	4,12	W2
16	7/1.73	5,18	W3
25	7/2.16	6,48	Y1
25	19/1.32	6,60	Y1
35	7/2.54	7,62	Y2
35	19/1.55	7,75	Y2
50	19/1.85	9,27	Y3
70	19/2.18	10,90	Y4
95	19/2.57	12,80	Y5
95	37/1.83	12,80	Y5
120	37/2.03	14,21	Y6
120	19/2.84	14,20	Y6
150	37/2.29	16,00	Y7
185	37/2.54	19,80	Y8
240	37/2.90	20,30	Y9
300	61/2.51	22,60	Y0

For other cable sizes or different stranding, please contact your local CADWELD distributor, agent or Pentair.

BUSBAR / TAPE KEY			
Thickness (mm)	CADWELD Code	Width (mm)	CADWELD Code
2	BA	20	H
3	CA	25	J
3,5	DA	30	K
4	EA	35	V
5	FA	40	L
6	PA	50	M
8	GA	60	N
10	HA	80	P
		100	Q

Ground Rods	
Size	CADWELD Code
7 mm	P070
10 mm	P100
12.7 mm	P128
14 mm	P140
14.2 mm	P143
15 mm	P150
16 mm	P160
17.2 mm	P172
19 mm	P190
20 mm	P200

Rebar	
Size	CADWELD Code
10 mm	51
12 mm	52
16 mm	53
20 mm	92
22 mm	55
25 mm	56
32 mm	58
36 mm	59
40 mm	83

# Metric to Imperial Conversion Chart

Metric Cables				US Equivalent			
Area Cross sectional area mm <sup>2</sup> (SQMM)	Metric Cable Code	Diameter		AWG/MCM Size	AWG/MCM Cable Code	Diameter	
		mm	Inch			Inch	mm
2.0 Concentric	—	1.8	0.071	#14 Concentric	—	0.0726	1.84
3.5 Concentric	G8	2.4	0.095	#12 Concentric	—	0.0915	2.3
w/B1331H sleeve (0.106 ID) - (2.69 mm)				—	—	—	—
4 Solid	G9	2.5	0.0984	#10 Solid	1A	0.102	2.6
6 Solid	H5	3.1	0.122	#8 Solid	1D	0.128	3.25
5.5 Concentric	B5	3.0	0.118	#10 Concentric	1B	0.116	2.95
w/B1331K sleeve (0.140 ID) - (3.56 mm)				—	—	—	—
8.0 Concentric	E0	3.6	0.142	#8 Concentric	1E	0.146	3.7
10 Solid	—	3.8	0.150	#6 Solid	1G	0.162	4.1
10 Concentric	W2	4.2	0.162	#7 Concentric	7L	0.164	4.2
14 Concentric	B0	4.8	0.189	#6 Concentric	1H	0.184	4.7
w/B1331H sleeve (0.106 ID) - (5.38 mm)				—	—	—	—
16 Solid	—	4.5	0.177	#4 Solid	1K	0.204	5.2
16 Concentric	W3	5.2	0.204	#5 Concentric	3Y	0.205	5.2
22 Concentric	A8	6.0	0.236	#4 Concentric	1L	0.232	5.9
25 Solid	W5	5.6	0.220	#3 Solid	1P	0.229	5.8
25 Concentric	Y1	6.4	0.260	#3 Concentric	1Q	0.260	6.6
25 Ropelay	X1	—	—	—	—	—	—
30 Concentric	A6	6.9	0.276	#2 Concentric	1V	0.292	7.4
35 Solid	W7	6.7	0.264	#2 Solid	1T	0.258	6.6
35 Concentric	Y2	7.7	0.305	#2 Concentric	1V	0.292	7.4
35 Ropelay	X2	—	—	—	—	—	—
38 Concentric	D5	7.8	0.315	#2 Concentric	1V	0.292	7.4
40 Concentric	E5	8.4	0.331	#1 Concentric	1Y	0.332	8.4
50 Solid	W6	8.0	0.315	1/0 Solid	2B	0.325	8.3
50 Concentric	Y3	9.0	0.354	1/0 Concentric	2C	0.373	9.5
50 Ropelay	X3	—	—	—	—	—	—
55 Concentric	G5	9.6	0.378	1/0 Concentric	2C	0.373	9.5
60 Concentric	L9	10.0	0.394	2/0 Concentric	2G	0.419	10.6
70 Solid	W8	10.0	0.394	3/0 Solid	2K	0.410	10.4
70 Concentric	Y4	10.9	0.430	2/0 Concentric	2G	0.419	10.6
70 Ropelay	—	—	—	—	—	—	—
80 Concentric	R4	11.5	0.453	3/0 Concentric	2L	0.470	12.0
95 Concentric	Y5	12.6	0.505	4/0 Concentric	2Q	0.528	13.4
95 Ropelay	X5	—	—	—	—	—	—
100 Concentric	X4	13.0	0.512	4/0 Concentric	2Q	0.528	13.4
120 Concentric	Y6	14.2	0.567	250MCM	2V	0.575	14.6
120 Ropelay	X6	—	—	—	—	—	—
125 Concentric	R6	14.5	0.571	250MCM	2V	0.575	14.6
150 Concentric	Y7	16.1	0.634	300MCM	3A	0.630	16.0
150 Ropelay	X7	—	—	—	—	—	—
160 Concentric	V7	—	—	—	—	—	—
185 Concentric	Y8	17.7	0.700	350MCM	3D	0.681	17.3
185 Ropelay	X8	—	—	—	—	—	—
200 Concentric	D7	18.2	0.717	400MCM	3H	0.728	18.5
240 Concentric	Y9	20.3	0.801	500MCM	3Q	0.813	20.7
240 Ropelay	X9	—	—	—	—	—	—
250 Concentric	V9	20.7	0.815	500MCM	3Q	0.813	20.7
300 Concentric	Y0	22.5	0.891	600MCM	3X	0.893	22.7
300 Ropelay	X0	—	—	—	—	—	—
315 Concentric	V0	—	—	—	—	—	—
325 Concentric	S4	23.4	0.922	700MCM	4G	0.964	24.5
400 Concentric	V1	26.2	1.03	800MCM	4Q	1.031	26.2
400 Ropelay	V6	—	—	—	—	—	—
500 Concentric	P9	28.8	1.13	1000MCM	4Y	1.152	29.3
500 Ropelay	W4	—	—	—	—	—	—
600 Concentric	R9	31.9	1.26	1200MCM	5G	1.263	32.1
625 Concentric	W9	32.8	1.29	1250MCM	5J	1.289	32.7
625 Ropelay	W0	—	—	—	—	—	—
725 Concentric	R0	35.2	1.39	1400MCM	5Q	1.364	34.6
800 Concentric	X8	36.8	1.45	1600MCM	5X	1.459	37.1
800 Ropelay	V2	—	—	—	—	—	—
850 Concentric	Q1	37.6	1.48	1700MCM	7G	1.506	38.2
1000 Concentric	V3	41.6	1.64	2000MCM	7G	1.632	41.5
1000 Ropelay	V4	—	—	—	—	—	—

F.1 - Metric Cable Sizes and Code, in Square Millimeters (MM<sup>2</sup>), abbrev. (QMM)

# CADWELD - Technical Advantages

## THE CADWELD WELD

- Has a current-carrying capacity equal to that of the conductor
- Creates a permanent bond that withstands repeated fault currents and will not loosen, deteriorate or increase in resistance
- Consistently performs the best in independent IEEE® 837 tests
- Is easy to check visibly for quality

## RELIABILITY

As the molecular bond eliminates the concept of surface contact, an electrolyte cannot penetrate between the conductors and cause oxidation and deterioration in the course of time.

## CORROSIVE ENVIRONMENTS

This reliability is of particular interest for humid or chemical environments or for bonds directly buried in the ground.

## ABILITY TO WITHSTAND HIGH CURRENT

The melting temperature of CADWELD connection is higher than the melting temperature of copper (1082°C). For this reason, in the event of abnormal heating due to a high fault current, the conductor is destroyed before the connection.

## CONDUCTIVITY

The CADWELD connections form a solid bond around the conductors assuring continuity. The cross sectional area of the weld has greater current carrying capacity than the conductors.


## PERFORMANCE

Standard CADWELD welds have a cross section greater than that of the conductors to be joined, which compensates for the difference in resistivity between the conductor and the welding material. Consequently, under fault conditions the weld will always remain cooler than the conductor.

If special applications do not allow for the required increase in cross section to be employed, the use of the formula:

$$R = \frac{\rho \times l}{S} \text{ and } V = R \times I$$

will make it possible to define precisely the resistance of the CADWELD weld.




## CORROSION TEST

This accelerated ageing test, carried out in a saline environment at a controlled temperature, demonstrates that CADWELD welds retain all their electrical properties during the period of the test whereas the resistance of mechanical connections increase with time and this alters their conductive properties.

CADWELD's exceptional performance is due to its reliability resulting from the molecular bond.


Comparison between CADWELD Bonded Connection and Mechanical Connection CADWELD Weld (Metal A) (Metal B).

The CADWELD bonded connection provides permanent conductivity over the whole of the section due to molecular bonding between the metal surfaces.



## Comparison between CADWELD Bonded Connection and Mechanical Connection


### CADWELD WELD



The CADWELD bonded connection provides conductivity over the whole of the section due to molecular bonding between the metal surfaces.

### MECHANICAL CRIMPED CONNECTION

Line of current



The mechanical connection presents a significant difference between the apparent contact surface and the actual surface.

# CADWELD - Technical Advantages

## GROUNDING SYSTEM – CONDUCTORS AND CONNECTORS

The grounding conductor size is based on the maximum magnitude and duration of available fault current, and on the type of connections being used in the grounding system.

IEEE® Std. 80-1986, Guide for Safety in Substation Grounding, uses a fusing formula as the basis for selecting minimum conductor size to avoid fusing (melting) under fault conditions.

This formula can be simplified to the following:

$$A = K \cdot I \sqrt{S}$$

Where: **A** = Conductor size in mm<sup>2</sup>  
**K** = Constant from the following table  
**I** = RMS fault current in amperes  
**S** = Fault time in seconds  
 Based on the standard ambient temperature of 40° C.

MAX TEMP	CONSTANT K FOR ABOVE FORMULA		
	COPPER (Soft Drawn)	COPPERWELD (Dead Soft Annealed) 40%	COPPERWELD (Dead Soft Annealed) 30%
1083° C	3.55	5.30	6.10
450° C	4.65	6.96	8.04
350° C	5.12	7.67	8.85
250° C	5.90	8.85	10.22

The temperatures listed above for each material are specified in IEEE Std. 80-1986 to be used for different types of connecting means;

- Pressure type connectors ..... 250° to 350° C\*
- Brazed connections ..... 450° C
- Exothermic welded connections ..... 1083° C

\*Except those that have been tested to and passed the requirements of IEEE Std. 837-1989.


### RELATIVE SIZES




Cable Only




CADWELD Connections



Brazed Connections



Pressure Type Connections 350°



Pressure Type Connections 250°

**EXAMPLE** – 25,000 Ampere, 2 second fault:

#### CONNECTION TYPE

CADWELD Electrical

#### CONDUCTOR SIZE

126 mm<sup>2</sup> - use 150 mm<sup>2</sup>

Brazed ..... 164 mm<sup>2</sup> - use 185 mm<sup>2</sup>

Pressure Type (at 350° C) ..... 181 mm<sup>2</sup> - use 185 mm<sup>2</sup>

Pressure Type (at 250° C) ..... 209 mm<sup>2</sup> - use 240 mm<sup>2</sup>



# Technical Information

## CADWELD THE MOLECULAR BOND

### CADWELD EXOTHERMIC CONNECTION

**A welding process that eliminates the connection by forming a molecular bond.**

Connections are the weak point of all electrical circuits and especially earthing circuits subjected to aging and corrosion. The capacity of an earthing circuit to protect the safety of personnel depends on the quality of the connections made.

#### **BS 6651 (1992) STATES :**

*"Any joint other than welded represents a discontinuity in the current conducting system and is susceptible to variation and failure."*

## CADWELD – The Molecular Bond

The CADWELD process provides a way to produce copper/copper, copper/galvanized or plain steel, copper/copper clad steel, copper/bronze/brass/stainless steel, steel/steel, molecular bonds with no external energy or heat source.

The principle consists of bringing together a welding materials and ignition agent in a suitable graphite mould.

The reduction of copper oxide by aluminium produces molten copper and aluminium oxide slag at extremely high temperatures.

The shape of the mould, its dimensions, and the size of the welding material, are all dependent on the items to be welded.


## Installation Is Easy!

### 4 Simple Steps For Permanently Welded Electrical Connections

The CADWELD PLUS Control Unit initiates the reaction of the metal crucible. The standard unit includes a 1.8 meter (6-foot) high temperature control unit lead. The lead attaches to the ignition strip using a custom made, purpose-designed termination clip.

After the termination clip is installed on the ignition strip, the installer pushes and holds the ignition button to start a charging and discharging sequence. Within a few seconds the control unit sends a predetermined voltage to the ignition strip and the reaction is initiated.

## THE CADWELD MOULD USING CADWELD PLUS



1  
Insert CADWELD PLUS package into mould



2  
Attach control unit termination clip to ignition strip



3  
Press and hold operating switch and wait for the ignition



4  
Open the mould and remove the expended steel cup – no special disposal required

# CADWELD PLUS

## CADWELD PLUS for Grounding Applications

CADWELD PLUS Part Number	Article Number	Size Identification Ring Color	Traditional Welding Material Part Number (Clear Cap)	Box Qty.
15PLUSF20	165700	Black	15	20
25PLUSF20	165701	Red	25	20
32PLUSF20	165702	White	32	20
45PLUSF20	165703	Light Blue	45	20
65PLUSF20	165704	Dark Green	65	20
90PLUSF20	165705	Gray	90	10
115PLUSF20	165706	Orange	115	10
150PLUSF20	165707	Dark Blue	150	10
200PLUSF20	165708	Yellow	200	10
250PLUSF20	165709	Purple	250	10
300PLUSF20	165710	Light Green	use 2 x 150	10
400PLUSF20	165711	Brown	use 2 x 200	10
500PLUSF20	165712	Light Brown	500	10



PLUSCU



Baffle Cover Kit



PLUSCULD

CADWELD PLUS Patent Numbers 6,553,911 6,835,910 6,703,578

## CADWELD PLUS for Cast Iron Applications

CADWELD PLUS Part Number	Article Number	Size Identification Ring Color	Traditional Welding Material Part Number (Orange Cap)	Box Qty.
25PLUSXF19	165718	Red	25XF19	20
32PLUSXF19	165719	White	32XF19	20
45PLUSXF19	165720	Light Blue	45XF19	20
65PLUSXF19	165721	Dark Green	65XF19	20

Gram weight PLUS welding material type i.e. 45PLUSF20

## Accessories

Part Number	Article Number	Description
PLUSCU	165738	CADWELD PLUS Control Unit
PLUSCU15L	165745	CADWELD PLUS Control Unit with 4.6 meters (15 ft.) Lead
PLUSCULD	165739	CONTROL UNIT Replacement Lead ) 1.8 meters (6 ft.)
PLUSCULD15	165746	CONTROL UNIT Replacement Lead 4.6 meters (15 ft.)
MC2X2KIT	165740	Kit, Baffle Cover, Graphite - 51 mm X 51 mm (2" X 2") Mould
MC25X3KIT	165744	Kit, Baffle Cover, Graphite - 64 mm X 76 mm (2½" X 3") Mould
MC3X3KIT	165741	Kit, Baffle Cover, Graphite - 76 mm X 76 mm (3" X 3") Mould
MC4X4KIT	165742	Kit, Baffle Cover, Graphite - 102 mm X 102 mm (4" X 4") Mould

# CADWELD MULTI

## 4 Easy steps for multiple, permanently welded, electrical connections



**Step 1** Layer batting and variable conductor sizes to be welded into dry mould



**Step 2** Close mould and drop metal disk in place




**Step 3** Dump welding material and tap bottom of container to release starting material



**Step 4** Close the cover and ignite with flint ignitor. Open the mould after 10 seconds



The CADWELD MULTI combines a versatile mould block and a range of gaskets (batting) to allow numerous different welded connections to be produced without the need to change the mould for each connection type.



The process is similar to the traditional CADWELD with one distinct difference... there is no need to change the mould for different connection types.

The whole process is complete in about one minute. The connection table details the gasket quantities required for each weld.

### CADWELD MULTI Available Items

Description	Part No.	Article No.		Box Qty.	Unit Weight (kg)
Kit for 20 welds, in metallic box 14" x 13" x 6" (360 x 330 x 160 mm)	KITCDM01	167780		1	10.00
Kit for 20 welds using CADWELD PLUS, in metallic box ( <b>Control Unit sold separately</b> ) 14" x 13" x 11" (360 x 330 x 280 mm)	KITCDM01 PLUS	167781		1	11.50
<b>Made from the following items which can be ordered separately:</b>			<b>Qty. in Kit</b>		
Mould	CDM01	234720	1	1	1.000
Handle Clamp	FMCDM01	120882	1	1	1.100
Set of 33 battings/gaskets	SCDM01	120886	2	1	0.200
Welding material 90*	90	163040	2 boxes of 10	10	0.090
CADWELD PLUS Welding Material**	90PLUSF20	165705	2 boxes of 10	10	0.158
Toolset TS-6A, including: • gloves • cardcloth brush • soft brush • flint ignitor	TS6A	169930	1	1	0.490

\* in KITCDM01 = Traditional CADWELD MULTI Kit  
\*\* in KITCDM01PLUS = CADWELD PLUS MULTI Kit

# CADWELD MULTI

## CADWELD MULTI Connection Capabilities

### Copper Cable/Solid to Copper Cable/Solid

**SS SC PA TA XA GG GJ**

**PP PK GE PG GF GW XB**

• Copper cable/solid sizes up to 1/0 (50 mm<sup>2</sup>) stranded or .40" (10 mm) diameter

**TD TE TF**

• Copper cable/solid sizes up to #3 (25 mm<sup>2</sup>) stranded or .26" (6,5 mm) diameter

### Copper Cable/Solid/Strip to Rebar

**RG RH RK RF RD**

• Copper conductor sizes up to 1/0 (50 mm<sup>2</sup>) stranded or .40" (10 mm) diameter  
 • Copper or steel strip/lug sizes up to 1" x .138" (30 x 3,5 mm)  
 • Rebar sizes up to #3 (10 mm)

### Copper Cable/Solid to Copper or Steel Strip/Lug

**HA HC HS HT GL LA LJ LE**

• Copper conductor sizes up to 1/0 (50 mm<sup>2</sup>) stranded or .40" (10 mm) diameter  
 • Copper or steel strip/lug sizes up to 1" x .138" (30 x 3,5 mm)

### Copper Strip to Copper Strip


**BB CG BG EB**

• BB and CG 1" x (.020" - .118"), (30 x 3,5 mm)  
 • BG and EB 1" x (.020" - .079"), (30 x 3 mm)

### Galvanized Steel Strip to Galvanized Steel Strip

**BB CG**

• Galvanized steel strip sizes up to 1" x .138" (30 x 3,5 mm)



## HORIZONTAL SPLICE

Splice of horizontal cables.

- Concentric stranded copper cable unless otherwise noted.
- Solid conductor may be copper or Copperweld®.
- Also available are splices of different and mixed cable sizes. For Copperweld DSA cables, contact Pentair.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320

## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111


# SS

CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
16*	SS <b>C</b> W3*	25
25	SS <b>C</b> Y1	32
35	SS <b>C</b> Y2	32
50	SS <b>C</b> Y3	45
70	SS <b>C</b> Y4	65
95	SS <b>C</b> Y5	90
120	SS <b>C</b> Y6	115
150	SS <b>C</b> Y7	115
185	SS <b>C</b> Y8	150
240	SS <b>C</b> Y9	200
300	SS <b>C</b> Y0	2 x 150**
8 mm Ø	SS <b>C</b> W6	45
10 mm Ø	SS <b>C</b> W8	65

\*Packing: B112, sleeve

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

\*\*For CADWELD PLUS use 300PLUSF20



## HORIZONTAL TEE CONNECTIONS

Tee of horizontal run and tap cables.

- Concentric stranded copper cable unless otherwise noted.
- Solid conductor can be copper or Copperweld®.
- **Bold letter** in mould part number is the price key.

### REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps	for C Price Key Moulds	161000 L160
	for D Price Key Moulds	161020 L159
CADWELD PLUS Control Unit or Flint Ignitor	165738	PLUSCU
	165000	T320

### SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	181225	B136A
#90 w/m & larger	181230	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111

## TA

CABLE SIZE (sq mm) run		MOULD PART NO. tap	WELDING MATERIAL <sup>1</sup>
16*	16*	TACW3W3	32
25	25	TAC <b>Y</b> 1Y1	32
25	16*	TAC <b>Y</b> 1W3	45
35	35	TAC <b>Y</b> 2Y2	45
35	25	TAC <b>Y</b> 2Y1	45
35	16*	TAC <b>Y</b> 2W3	45
50	50	TAC <b>Y</b> 3Y3	90
50	35	TAC <b>Y</b> 3Y2	45
50	25	TAC <b>Y</b> 3Y1	45
50	16*	TAC <b>Y</b> 3W3	45
70	70	TAC <b>Y</b> 4Y4	90
70	50	TAC <b>Y</b> 4Y3	90
70	35	TAC <b>Y</b> 4Y2	45
70	25	TAC <b>Y</b> 4Y1	45
70	16*	TAC <b>Y</b> 4W3	45
95	95	TAC <b>Y</b> 5Y5	115
95	70	TAC <b>Y</b> 5Y4	90
95	50	TAC <b>Y</b> 5Y3	90
95	35	TAC <b>Y</b> 5Y2	90
95	25	TAC <b>Y</b> 5Y1	90
95	16*	TAC <b>Y</b> 5W3	90


\*Packing: B112, sleeve

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

CABLE SIZE (sq mm) run		MOULD PART NO. tap	WELDING MATERIAL <sup>1</sup>
120	120	TAC <b>Y</b> 6Y6	150
120	95	TAC <b>Y</b> 6Y5	150
120	70	TAC <b>Y</b> 6Y4	90
120	50	TAC <b>Y</b> 6Y3	90
120	35	TAC <b>Y</b> 6Y2	90
150	150	TAC <b>Y</b> 7Y7	200
150	120	TAC <b>Y</b> 7Y6	150
150	95	TAC <b>Y</b> 7Y5	150
150	70	TAC <b>Y</b> 7Y4	90
185	185	TAC <b>Y</b> 8Y8	200
185	150	TAC <b>Y</b> 8Y7	200
185	120	TAC <b>Y</b> 8Y6	200
240	240	TAC <b>Y</b> 9Y9	2 x 150**
240	185	TAC <b>Y</b> 9Y8	200
240	150	TAC <b>Y</b> 9Y7	200
240	120	TAC <b>Y</b> 9Y6	200
8 mm Ø	8 mm Ø	TACW6W6	90
10 mm Ø	8 mm Ø	TACW8W6	90
10 mm Ø	10 mm Ø	TACW8W8	90

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

\*\*For CADWELD PLUS use 300PLUSF20



## XA

CABLE SIZE (sq mm)		MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
run	tap		
25	25	XAC <b>Y</b> 1Y1	45
35	35	XAC <b>Y</b> 2Y2	65
35	25	XAC <b>Y</b> 2Y1	65
50	50	XAC <b>Y</b> 3Y3	90
50	35	XAC <b>Y</b> 3Y2	90
70	70	XAC <b>Y</b> 4Y4	115
70	50	XAC <b>Y</b> 4Y3	115
95	95	XAC <b>Y</b> 5Y5	200
95	70	XAC <b>Y</b> 5Y4	150
95	50	XAC <b>Y</b> 5Y3	150
120	120	XAC <b>Y</b> 6Y6	200
120	95	XAC <b>Y</b> 6Y5	200
120	70	XAC <b>Y</b> 6Y4	200
150	150	XAC <b>Y</b> 7Y7	250
150	120	XAC <b>Y</b> 7Y6	250
150	95	XAC <b>Y</b> 7Y5	200
150	70	XAC <b>Y</b> 7Y4	200
185	185	XAC <b>Y</b> 8Y8	250
185	150	XAC <b>Y</b> 8Y7	250
185	120	XAC <b>Y</b> 8Y6	250
240	240	XAD <b>Y</b> 9Y9	500
240	185	XAD <b>Y</b> 9Y8	2 x 200*
240	150	XAD <b>Y</b> 9Y7	2 x 200*
240	120	XAD <b>Y</b> 9Y6	2 x 150**

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

\*For CADWELD PLUS use 400PLUSF20

\*\*For CADWELD PLUS use 300PLUSF20

## HORIZONTAL X CONNECTIONS

**XA** – Cross of horizontal cables, tap cable cut – cables in same plane.

**XB** – Cross of horizontal cables, lapped and not cut.

- Concentric stranded copper cable unless otherwise noted
- Solid conductor may be copper or Copperweld®.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

	Article No.	Part No.	
Handle Clamps	for C Price Key Moulds	161000	L160
	for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738	PLUSCU	
	165000	T320	

## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111

## ADDITIONAL NOTES

- B136C cleaning tool supplied with each XB mould.
- All Q price moulds require L160 handle clamp.
- All Z price moulds require L159 handle clamp.

## XB


CABLE SIZE (sq mm)		MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
run	tap		
25	25	XBC <b>Y</b> 1Y1	65
35	35	XBC <b>Y</b> 2Y2	90
50	50	XB <b>Q</b> Y3Y3	150
70	70	XB <b>Q</b> Y4Y4	200
95	95	XB <b>Q</b> Y5Y5	250
120	120	XB <b>Q</b> Y6Y6	2 x 150**
150	150	XB <b>Z</b> Y7Y7	2 x 200*
185	185	XB <b>Z</b> Y8Y8	500
240	240	XB <b>Z</b> Y9Y9	3 x 250***

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

\*For CADWELD PLUS use 400PLUSF20

\*\*For CADWELD PLUS use 300PLUSF20

\*\*\*For CADWELD PLUS use 750PLUSF20



## PARALLEL HORIZONTAL CONDUCTORS

Parallel through connection of horizontal cables.

- Run conductor is on the bottom of type PT moulds.
- Concentric strand copper cable unless otherwise noted.
- Solid conductor may be copper or Copperweld®.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps	for C Price Key Moulds	161000 L160
	for D Price Key Moulds	161020 L159
CADWELD PLUS Control Unit or Flint Ignitor	165738	PLUSCU
	165000	T320

## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111

**PT**

CABLE SIZE (sq mm) run		MOULD PART NO. tap	WELDING MATERIAL <sup>1</sup>
25	25	PT <b>C</b> Y1Y1	45
35	35	PT <b>C</b> Y2Y2	65
35	25	PT <b>C</b> Y2Y1	65
50	50	PT <b>C</b> Y3Y3	90
50	35	PT <b>C</b> Y3Y2	65
70	70	PT <b>C</b> Y4Y4	115
70	50	PT <b>C</b> Y4Y3	115
95	95	PT <b>C</b> Y5Y5	200
95	70	PT <b>C</b> Y5Y4	150
95	50	PT <b>C</b> Y5Y3	150
120	120	PT <b>C</b> Y6Y6	250
120	95	PT <b>C</b> Y6Y5	200
120	70	PT <b>C</b> Y6Y4	150
150	150	PT <b>D</b> Y7Y7	2 x 150*
150	120	PT <b>C</b> Y7Y6	250
150	95	PT <b>C</b> Y7Y5	200
150	70	PT <b>C</b> Y7Y4	150
185	185	PT <b>D</b> Y8Y8	2 x 150*
185	150	PT <b>D</b> Y8Y7	2 x 150*
185	120	PT <b>C</b> Y8Y6	250
240	240	PT <b>D</b> Y9Y9	2 x 200**
240	185	PT <b>D</b> Y9Y8	2 x 150*
240	150	PT <b>D</b> Y9Y7	2 x 150*
240	120	PT <b>C</b> Y9Y6	250

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)



\*For CADWELD PLUS use 300PLUSF20

\*\*For CADWELD PLUS use 400PLUSF20



## HA

Cable on surface



## HS

Cable off surface

## HA

CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
25	HAA <b>Y</b> 1	45
35	HAA <b>Y</b> 2	45
50	HAA <b>Y</b> 3	45
70	HAA <b>Y</b> 4	65

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

## HS

CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
95	HSC <b>Y</b> 5	115
120	HSC <b>Y</b> 6	115
150	HSC <b>Y</b> 7	150
185	HSC <b>Y</b> 8	200
240	HSC <b>Y</b> 9	200

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

## HORIZONTAL STEEL SURFACE

Horizontal concentric copper conductor to flat steel surface or top of horizontal pipe

- CADWELD also has a complete product line for cathodic protection connections. See catalogue CA1A.
- A test weld should be made to check the possibility of burn-through on thin sections or thin wall pipe.
- Concentric stranded copper cable listed.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

No.	Article No.	Part
Handle Clamps*		
Flat Surface	for C Price Key Moulds 161000	L160
	for D Price Key Moulds 161020	L159
Pipe (curved surface)	for C Price Key Moulds	B160V
	for D Price Key Moulds	B159V
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320

## SUGGESTED TOOLS

Conductor Cleaning Brush	165030	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111
Rasp	162420	T321


\*Handles are included with A Price Key Moulds.

## Cable to Steel Pipe (Types HA and HS) –


Use flat surface mould part number with suffix.

Cable	Nominal Pipe Diameter	Suffix
35 mm <sup>2</sup> and Smaller	Less than 350 mm	Nominal Diameter (mm)
	Greater than 350 mm	None
50 mm <sup>2</sup> thru 120 mm <sup>2</sup>	Less than 760 mm	Nominal Diameter (mm)
	Greater than 762 mm	None

Example: 35 mm<sup>2</sup> cable, on 100 mm diameter pipe HAA-Y2-100  
95 mm<sup>2</sup> cable on 250 mm diameter pipe HSC-Y5-250



VS



VS

CABLE SIZE sq mm	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
25	VSCY1	45
35	VSCY2	45
50	VSCY3	90
70	VSCY4	90
95	VSCY5	115
120	VSCY6	115
150	VSCY7	150
185	VSCY8	200
240	VSCY9	200

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

## VERTICAL STEEL SURFACE

Cable down at 45° to vertical steel surface including pipe.  
Cable to vertical flat steel surface; cable to side of vertical or horizontal steel pipe.

- CADWELD also has a complete product line for cathodic protection connections.
- Concentric stranded copper cable listed.
- A test weld should be made to check the possibility of burn through on thin sections or thin wall pipe.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

		Article No.	Part No.
Handle Clamps			
Flat Surface	for C Price Key Moulds	161000	L160
	for D Price Key Moulds	161020	L159
Pipe (to 100 mm dia.)	for C Price Key Moulds		B160V
	for D Price Key Moulds		B159V
	(Pipes 10ø-250 mm dia. add B158)		
CADWELD PLUS Control Unit or Flint Ignitor		165738	PLUSCU
		165000	T320

## SUGGESTED TOOLS

Conductor Cleaning Brush	165030	T313
Slag Removal Spade	See CADWELD Table	
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111
Rasp	162420	T321

## ADDITIONAL NOTES

For flat vertical surfaces, on an H column or angle, the following attachment can be used to secure the mould.


for use with L160	B134
for use with L159	B135

## Cable to Vertical Steel Pipe –


Use flat surface mould part number; add **V** and suffix.

Cable	Nominal Pipe Diameter	Suffix
25 mm <sup>2</sup> thru 120 mm <sup>2</sup>	Less than 80 mm 812.8 mm and larger	Nominal Pipe Diameter None

Example: 70 mm<sup>2</sup> to 102 mm pipe, VSC-Y4-102V



**HX**  
Vertical stud to horizontal steel surface



**HV**  
Horizontal stud to horizontal steel surface

## STEEL STUDS

Connections of steel studs to steel surfaces. Studs on grounded structures provide a convenient point of attachment of temporary protective ground clamps.

- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

		Article No.	Part No.
Handle Clamps	for C Price Key Moulds	161000	L160
	for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor		165738	PLUSCU
		165000	T320

## SUGGESTED TOOLS

Mould Cleaning Brush	165260	T394
Rasp	162420	T321
Torch Head	140160	T111
Mould Scraper Tool	#65 w/m & smaller	B136A
	#90 w/m & larger	B136B

## HX


THREAD DESCRIPTION	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
M6	HXC-6	25
M8	HXC-8	32
M10	HXC-10	45
M12	HXC-12	45
M16	HXC-16	90

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)


## HV

THREAD DESCRIPTION	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
M6	HVC-6	25
M10	HVC-P100	45
M12	HVC-P120	65
M16	HVC-P160	115

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)



**BA**



**BB**

## COPPER BUSBAR SPLICE

**TYPE BA** – Horizontal, on-edge, busbar.

**TYPE BB** – Horizontal busbars.

• **Bold letter** in mould part number is the price key.

### REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps	for C Price Key Moulds	161000 L160
	for D Price Key Moulds	161020 L159
CADWELD PLUS Control Unit or Flint Ignitor	165738	PLUSCU
	165000	T320

### SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111

## BA


BUSBAR SIZE	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
3X25	BAC <b>CAJ</b>	65
3X50	BAC <b>CAM</b>	90
4X40	BAC <b>EAL</b>	115
4X50	BAC <b>EAM</b>	115
5X40	BAC <b>FAL</b>	150
5X50	BAC <b>FAM</b>	200
6X25	BAC <b>PAJ</b>	115
6X50	BAC <b>PAM</b>	150

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)


## BB

BUSBAR SIZE	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
3X25	BB <b>CAJ</b>	90
3X50	BB <b>RCAM</b>	150
4X40	BB <b>CEAL</b>	150
4X50	BB <b>REAM</b>	150
5X40	BB <b>CFAL</b>	150
5X50	BB <b>RFAM</b>	200
6X25	BB <b>CPAJ</b>	115
6X50	BB <b>RPAM</b>	250

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)



**BM**



**BQ**

**BM**

BUSBAR SIZE	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
3X25 3X50	BM <b>C</b> CAJCAJ BM <b>D</b> CAMCAM	90 250
4X40 4X50	BM <b>C</b> EALEAL BM <b>D</b> EAMEAM	150 200
5X40 5X50	BM <b>C</b> FALFAL BM <b>D</b> FAMFAM	150 200
6X25 6X50	BM <b>C</b> PAJPAJ BM <b>D</b> PAMPAM	115 250

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

## COPPER BUSBAR

**TYPE BM** – Tee tap – horizontal busbars.

**TYPE BQ** – Tee tap down – horizontal, on-edge, busbars.

- **Bold letter** in mould part number is the price key.

### REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320

### SUGGESTED TOOLS


Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111

**BQ**

BUSBAR SIZE	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
3X25 3X50	BQ <b>C</b> CAJCAJ BQ <b>C</b> CAMCAM	90 200
4X40 4X50	BQ <b>C</b> EALEAL BQ <b>C</b> EAMEAM	150 200
5X40 5X50	BQ <b>C</b> FALFAL BQ <b>C</b> FAMFAM	150 200
6X25 6X50	BQ <b>C</b> PAJPAJ BQ <b>D</b> PAMPAM	150 2 x 250*

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

\*For CADWELD PLUS use 500PLUSF20



**LE**

CABLE SIZE (sq mm)	BUSBAR (mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
16	2x20	LECW3BAH*	45
	2x25	LECW3BAJ*	65
	3x20	LECW3CAH*	65
	3x25	LECW3CAJ*	65
25	2x20	LECY1BAH	45
	2x25	LECY1BAJ	45
	3x20	LECY1CAH	45
	3x25	LECY1CAJ	45
	4x25	LECY1EAJ	65
35	2x25	LECY2BAJ	45
	3x20	LECY2CAH	45
	3x25	LECY2CAJ	45
	4x25	LECY2EAJ	65
50	2x25	LECY3BAJ	65
	3x20	LECY3CAH	65
	3x25	LECY3CAJ	65
	4x25	LECY3EAJ	90
70	3x25	LECY4CAJ	90
	3x30	LECY4CAK	90
	4x25	LECY4EAJ	115
	4x30	LECY4EAK	115
	5x30	LECY4FAK	115
95	3x25	LECY5CAJ	90
	3x30	LECY5CAK	90
	4x25	LECY5EAJ	150
	4x30	LECY5EAK	150
	5x30	LECY5FAK	150
	6x40	LECY5PAL	200
120	3x25	LECY6CAJ	115
	3x30	LECY6CAK	115
	4x25	LECY6EAJ	150
	4x30	LECY6EAK	150
	5x30	LECY6FAK	200
	6x40	LECY6PAL	200

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

\* Requires B112 Sleeve

## CABLE TO BUSBAR

Horizontal tee - tap of copper busbar to cable run


- Concentric stranded copper cable as listed
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320

## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111



## BUSBAR TO BUSBAR

Horizontal X - bars flat and in same plane

- **Bold letter** in mould part number is the price key.

### REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320


### SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111


**EB**

BUSBAR (mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
3X25	EB <b>CCA</b> J	115
3X30	EB <b>CCA</b> K	115
3X50	EB <b>CCA</b> M	200
4X40	EB <b>CEA</b> L	200
4X50	EB <b>CEA</b> M	250
5X40	EB <b>CFA</b> L	250
5X50	EB <b>CFA</b> M	250
6X25	EB <b>CPA</b> J	200
6X50	EB <b>CPA</b> M	200

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)



**BW**



**CG**

### BUSBAR TO BUSBAR

**BW** - Vertical rising copper busbar to a flat, vertical steel surface

**CG** - Horizontal tee - tap of copper busbar to busbar run

- A test weld should be made to check the possibility of burn through when intended for use on thin sections or thin wall pipe.
- **Bold letter** in mould part number is the price key.

### REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320

### SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111
Rasp	162420	T321

## BW

BUSBAR SIZE	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
3X25 3X50	BW <b>C</b> CAJ BW <b>C</b> CAM	90 150
4X40 4X50	BW <b>C</b> EAL BW <b>C</b> EAM	200 250
5X40 5X50	BW <b>C</b> FAL BW <b>D</b> FAM	200 250
6X25 6X50	BW <b>C</b> PAJ BW <b>D</b> PAM	150 2 x 150*

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)


\*For CADWELD PLUS use 300PLUSF20

## CG

BUSBAR SIZE	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
3X25 3X50	CG <b>C</b> CAJ CG <b>C</b> CAM	115 200
4X25 4X50	CG <b>C</b> EAJ CG <b>C</b> EAM	150 250
5X40 5X50	CG <b>C</b> FAL CG <b>C</b> FAM	200 250
6X25 6X50	CG <b>C</b> PAJ CG <b>C</b> PAM	150 300

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)





LJ

BUSBAR (mm)	CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
3 x 25	35	LJ <b>CA</b> JY2	45
	50	LJ <b>CA</b> JY3	90
	70	LJ <b>CA</b> JY4	90
4 x 40 & WIDER	35	LJ <b>CE</b> ALY2	45
	50	LJ <b>CE</b> ALY3	90
	70	LJ <b>CE</b> ALY4	90
	95	LJ <b>CE</b> ALY5	90
	120	LJ <b>CE</b> ALY6	90
	150	LJ <b>CE</b> ALY7	115
	185	LJ <b>CE</b> ALY8	150
	240	LJ <b>CE</b> ALY9	150
	5 x 40 & WIDER	35	LJ <b>CF</b> FALY2
50		LJ <b>CF</b> FALY3	90
70		LJ <b>CF</b> FALY4	90
95		LJ <b>CF</b> FALY5	90
120		LJ <b>CF</b> FALY6	115
150		LJ <b>CF</b> FALY7	115
185		LJ <b>CF</b> FALY8	150
240		LJ <b>CF</b> FALY9	200
6 x 40 & WIDER		35	LJ <b>CP</b> PALY2
	50	LJ <b>CP</b> PALY3	90
	70	LJ <b>CP</b> PALY4	90
	95	LJ <b>CP</b> PALY5	90
	120	LJ <b>CP</b> PALY6	115
	150	LJ <b>CP</b> PALY7	115
	185	LJ <b>CP</b> PALY8	150
	240	LJ <b>CP</b> PALY9	200

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

## CABLE TO BUSBAR

Tap of horizontal cable to edge of horizontal, flat busbar.


- Concentric stranded copper cable is listed.
- The minimum distance between adjacent welds is indicated as "C" dimension.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320

## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111



LA

CABLE SIZE (sq mm)	BUS OR LUG SIZE (mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
16	2 x 20	LAC-W3-BAH	32
	2 x 25	LAC-W3-BAJ	32
	3 x 20	LAC-W3-CAH	45
	3 x 25	LAC-W3-CAJ	45
25	2 x 25	LAC-Y1-BAJ	45
	3 x 20	LACY1-CAH	45
	3 x 25	LAC-Y1-CAJ	45
	4 x 25	LAC-Y1-EAJ	65
35	2 x 25	LAC-Y2-BAJ	45
	3 x 20	LACY2-CAH	45
	3 x 25	LAC-Y2-CAJ	45
	4 x 25	LAC-Y2-EAJ	45
50	2 x 25	LAC-Y3-BAJ	45
	3 x 20	LAC-Y3-CAH	45
	3 x 25	LAC-Y3-CAJ	45
	4 x 25	LAC-Y3-EAJ	65
70	3 x 25	LAC-Y4-CAJ	65
	3 x 30	LAC-Y4-CAK	65
	4 x 25	LAC-Y4-EAJ	65
	4 x 30	LAC-Y4-EAK	65
	5 x 30	LAC-Y4-FAK	90
95	3 x 25	LAC-Y5-CAJ	65
	3 x 30	LAC-Y5-CAK	90
	4 x 25	LAC-Y5-EAJ	90
	4 x 30	LAC-Y5-EAK	90
	5 x 30	LAC-Y5-FAK	90
120	3 x 25	LAC-Y6-CAJ	90
	3 x 30	LAC-Y6-CAK	90
	4 x 25	LAC-Y6-EAJ	90
	4 x 30	LAC-Y6-EAK	90
	5 x 30	LAC-Y6-FAK	90

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

## COPPER LUGS (METRIC)


- Lugs and connections for equipment and structures. Ideal for power utility applications.
- Concentric stranded copper cable is listed.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS


	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320

## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111




**GL**



### NEMA® Drilled Lugs-B-121 Series

All lugs are tin plated copper.



### NEMA Drilled Lugs-B-122 Series

## COPPER LUGS

- Lugs and connections for equipment and structures. Ideal for power applications.
- Concentric stranded copper cable is listed.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320


## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111

**GL**

CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>	LUG SIZE T X W (mm)	GL LUG NUMBER	
				1 HOLE	2 HOLE
25	GL <b>C</b> CEY1	32	3.18 x 25.4	B-121-CE	B-122-CE
35	GL <b>C</b> CEY2	32	3.18 x 25.4	B-121-CE	B-122-CE
50	GL <b>C</b> CEY3	45	3.18 x 25.4	B-121-CE	B-122-CE
70	GL <b>C</b> CEY4	45	3.18 x 25.4	B-121-CE	B-122-CE
95	GL <b>C</b> DEY5	65	4.76 x 25.4	B-121-DE	B-122-DE
120	GL <b>C</b> DEY6	65	4.76 x 25.4	B-121-DE	B-122-DE
150	GL <b>C</b> EEY7	90	6.35 x 25.4	B-121-EE	B-122-EE
185	GL <b>C</b> EEY8	90	6.35 x 25.4	B-121-EE	B-122-EE
240	GL <b>C</b> EGY9	150	6.35 x 38.1	B-121-EG	B-122-EG

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)



**GR**

**GR**

GROUND ROD SIZE Dia. (mm)	CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
12.7	25	GR <b>C</b> P128Y1	65
	35	GR <b>C</b> P128Y2	65
	50	GR <b>C</b> P128Y3	65
	70	GR <b>C</b> P128Y4	90
	95	GR <b>C</b> P128Y5	90
	120	GR <b>C</b> P128Y6	90
	150	GR <b>C</b> P128Y7	115
	185	GR <b>C</b> P128Y8	115
14.2	25	GR <b>C</b> P143Y1	65
	35	GR <b>C</b> P143Y2	90
	50	GR <b>C</b> P143Y3	90
	70	GR <b>C</b> P143Y4	90
	95	GR <b>C</b> P143Y5	90
	120	GR <b>C</b> P143Y6	90
	150	GR <b>C</b> P143Y7	115
	185	GR <b>C</b> P143Y8	150
	240	GR <b>C</b> P143Y9	250
17.2	25	GR <b>C</b> P173Y1	90
	35	GR <b>C</b> P173Y2	90
	50	GR <b>C</b> P173Y3	90
	70	GR <b>C</b> P173Y4	90
	95	GR <b>C</b> P173Y5	90
	120	GR <b>C</b> P173Y6	90
	150	GR <b>C</b> P173Y7	115
	185	GR <b>C</b> P173Y8	115
	240	GR <b>C</b> P173Y9	150

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

## CABLE TO GROUND ROD


- Single cable to top of ground rod. Concentric strand copper cable unless otherwise noted. For copperclad, galvanized, stainless clad or stainless steel ground rods.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320

## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
File	165260	T329
Torch Head	140160	T111



## CABLE TO GROUND ROD

- Through cable to top of ground rod. Connections are for concentric strand copper cable unless otherwise noted. For copperclad, galvanized, stainless clad or stainless steel ground rods.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320


## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
File	165260	T329
Torch Head	140160	T111

## GT

GROUND ROD SIZE Dia. (mm)	CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
12.7	25	G <b>T</b> CP128Y1	90
	35	G <b>T</b> CP128Y2	90
	50	G <b>T</b> CP128Y3	90
	70	G <b>T</b> CP128Y4	90
	95	G <b>T</b> CP128Y5	115
	120	G <b>T</b> CP128Y6	150
	150	G <b>T</b> CP128Y7	150
	185	G <b>T</b> CP128Y8	200
14.2	25	G <b>T</b> CP143Y1	90
	35	G <b>T</b> CP143Y2	90
	50	G <b>T</b> CP143Y3	90
	70	G <b>T</b> CP143Y4	115
	95	G <b>T</b> CP143Y5	115
	120	G <b>T</b> CP143Y6	150
	150	G <b>T</b> CP143Y7	200
	185	G <b>T</b> CP143Y8	200
	240	G <b>T</b> CP143Y9	250
17.2	25	G <b>T</b> CP173Y1	90
	35	G <b>T</b> CP173Y2	90
	50	G <b>T</b> CP173Y3	90
	70	G <b>T</b> CP173Y4	115
	95	G <b>T</b> CP173Y5	115
	120	G <b>T</b> CP173Y6	150
	150	G <b>T</b> CP173Y7	200
	185	G <b>T</b> CP173Y8	200
	240	G <b>T</b> CP173Y9	250

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)



**GY**

**GY**

GROUND ROD SIZE Dia. (mm)	CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
12.7	25	GY <b>RP</b> 128Y1	90
	35	GY <b>RP</b> 128Y2	90
	50	GY <b>RP</b> 128Y3	115
	70	GY <b>RP</b> 128Y4	115
	95	GY <b>RP</b> 128Y5	150
	120	GY <b>RP</b> 128Y6	150
	150	GY <b>RP</b> 128Y7	200
	185	GY <b>RP</b> 128Y8	200
14.2	25	GY <b>RP</b> 143Y1	90
	35	GY <b>RP</b> 143Y2	90
	50	GY <b>RP</b> 143Y3	115
	70	GY <b>RP</b> 143Y4	115
	95	GY <b>RP</b> 143Y5	150
	120	GY <b>RP</b> 143Y6	150
	150	GY <b>RP</b> 143Y7	200
	185	GY <b>RP</b> 143Y8	250
	240	GY <b>FP</b> 143Y9	2 x 200*
17.2	25	GY <b>RP</b> 173Y1	90
	35	GY <b>RP</b> 173Y2	90
	50	GY <b>RP</b> 173Y3	115
	70	GY <b>RP</b> 173Y4	150
	95	GY <b>RP</b> 173Y5	150
	120	GY <b>RP</b> 173Y6	250
	150	GY <b>RP</b> 173Y7	250
	185	GY <b>FP</b> 173Y8	2 x 200*
	240	GY <b>FP</b> 173Y9	2 x 200*

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

\*For CADWELD PLUS use 400PLUSF20

## CABLE TO GROUND ROD


- Through cable to side of ground rod.
- Concentric strand copper cable unless otherwise noted.
- Ground rods can be copperclad, galvanized, stainless clad or stainless steel.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps	for C Price Key Moulds	161000 L160
	for D Price Key Moulds	161020 L159
CADWELD PLUS Control Unit or Flint Ignitor	165738	PLUSCU
	165000	T320

## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
File	165260	T329
Torch Head	140160	T111




**LQ**

**LQ**


GROUND ROD SIZE Diam. (mm)	BUSBAR SIZE (mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>
12.7	3 x 25	LQ <b>E</b> -P128-CAJ	200
14.2	3 x 25	LQ <b>E</b> -P143-CAJ	200
17.2	3 x 25	LQ <b>E</b> -P173-CAJ	2 x 200*

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

\*For CADWELD PLUS use 400PLUSF20



**CP**



**CN**

## BUSBAR TO GROUND ROD

**TYPE CP** - Through busbar to top of ground rod.

**TYPE CN** - Busbar tap to top of ground rod.

- Ground rods can be copperbonded, copperclad, galvanized, stainless steel or stainless steel clad.
- **Bold letter** in mould part number is the price key.

### REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps		
for C Price Key Moulds	161000	L160
for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320

### SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
Torch Head	140160	T111


## CP

GROUND ROD SIZE (sq mm dia)	BUSBAR (mm)	MOULD PART NO.	WELDING MATERIAL
12.7	2 x 30	C <b>CP</b> 128BAK	115
14.2		C <b>CP</b> 148BAK	115
17.2		C <b>CP</b> 178BAK	115
12.7	3 x 25	C <b>CP</b> 128CAJ	150
14.2		C <b>CP</b> 142CAJ	115
17.2		C <b>CP</b> 172CAJ	200
12.7	6 x 50 (or wider)	C <b>CP</b> 128PAM	150
14.2		C <b>CP</b> 142PAM	200
17.2		C <b>CP</b> 172PAM	250

## CN

GROUND ROD SIZE (sq mm dia)	BUSBAR (mm)	MOULD PART NO.	WELDING MATERIAL
12.7	2 x 30	C <b>N</b> CP128BAK	115
14.2		C <b>N</b> CP148BAK	115
17.2		C <b>N</b> CP178BAK	150
12.7	3 x 25	C <b>N</b> CP128CAJ	90
14.2		C <b>N</b> CP142CAJ	150
17.2		C <b>N</b> CP172CAJ	150
12.7	6 x 50 (or wider)	C <b>N</b> CP128PAM	200
14.2		C <b>N</b> CP142PAM	250
17.2		C <b>N</b> CP172PAM	2 x 150*

\* For CADWELD PLUS use 300PLUSF20



CADWELD ONE SHOT connections are available in standard packages of 6 each.

## CABLE TO GROUND ROD USING CADWELD ONE SHOT CONNECTIONS

For both plain or threaded copperclad and galvanized steel or stainless steel rods. The CADWELD ONE SHOT case is a ceramic disposable body replacing the familiar semi-permanent graphite mould and associated handle clamp. Everything required is included except control unit.

Meets NEC® requirements

### REQUIRED TOOLS

	Article No.	Part No.
CADWELD PLUS Control Unit or Flint Ignitor	165738 165000	PLUSCU T320


### SUGGESTED TOOLS

Cable Cleaning Brush	165030	T313
File	165260	T329
Torch Head	140160	T111

GROUND ROD SIZE Dia. (mm)	CONDUCTOR SIZE (mm²)	PART NUMBER	
		TYPE GR <sup>1</sup>	TYPE GT <sup>1</sup>
12.7	8-10	GR1-141G	GT1 -141G
	14-22	GR1-141L	GT1 -141L
	25	GR1-141Q	GT1-141Q
	30-38	GR1-141V	GT1 -141V
14.2	8-10	GR1-161G	GT1-161G
	14-22	GR1-161L	GT1-161L
	25	GR1-161Q	GT1-161Q
	30-38	GR1-161V	GT1-161V
	50-60	GR1-162C	GT1-162C
	70 sq mm	GR1-162G	
17.2	8-10	GR1-181G	GT1-181G
	14-22	GR1-181L	GT1-181L
	25	GR1-181Q	GT1-181Q
	30-38	GR1-181V	GT1-181V
	50-60	GR1-182C	GT1-182C
	70 sq mm	GR1-182G	

<sup>1</sup> For CADWELD PLUS ONE SHOT add suffix "PLUS" following the above part number





**GB**

## GROUND ROD SPLICE

- CADWELD ground rod splices are very strong and use the proven corrosion resistant CADWELD connection.
- CADWELD ground rod splices are available for copperclad, galvanized or stainless ground rods.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

	Article No.	Part No.
Handle Clamps	for C Price Key Moulds	161000 L160
	for D Price Key Moulds	161020 L159
CADWELD PLUS Control Unit or Flint Ignitor	165738	PLUSCU
Ground Rod Splice Clamp	165000	T320 B120


## SUGGESTED TOOLS

Conductor Cleaning Brush	165130	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
Cable Clamp	165020	B265
File	165260	T329
Torch Head	140160	T111

**GB**

GROUND ROD SIZE Dia. (mm)	MOULD PART NO.	WELDING MATERIAL
12.7	HDGBC14	250*
14.2	HDGBC16	2 x 150**
17.2	HDGBC18	2 x 200***


- \*For CADWELD PLUS use 250PLUSF20
- \*\*For CADWELD PLUS use 300PLUSF20
- \*\*\*For CADWELD PLUS use 400PLUSF20



161750

## Ground Rod Splice Clamp

The B120 Ground Rod Splice Clamp must be used to support the upper rod and provide a method of correctly positioning the rods and mould while splicing the rods. (Type HDGB Connection).



**RR**

## CABLE TO REBAR

Horizontal cable tap to horizontal rebar.

- Rebar material characteristics and location of weld must be considered when selecting connections to rebar.
- Concentric stranded copper cable is listed.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

		Article No.	Part No.
Handle Clamps	for C Price Key Moulds	161000	L160
	for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor		165738	PLUSCU T320
Packing Material	One required for each connection - see tables below		

## SUGGESTED TOOLS

Cable Cleaning Brush	165030	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
File	165260	T329
Torch Head	140160	T111


**RR**

REBAR SIZE Diam (mm)	CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>	PACKING MATERIAL
12	25	RR <b>A</b> 52Y1	45	B143A
	35	RR <b>A</b> 52Y2	45	B143A
	50	RR <b>C</b> 52Y3	90	B141A
	70	RR <b>C</b> 52Y4	90	B141A
	95	RR <b>C</b> 52Y5	115	B141A
16	25	RR <b>A</b> 53Y1	45	B143A
	35	RR <b>A</b> 53Y2	45	B143A
	50	RR <b>C</b> 53Y3	90	B141A
	70	RR <b>C</b> 53Y4	90	B141A
	95	RR <b>C</b> 53Y5	115	B141A

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

REBAR SIZE Diam (mm)	CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>	PACKING MATERIAL
22	35	RR <b>A</b> 55Y2	45	B143B
	50	RR <b>H</b> 55Y3	90	B144C
	70	RR <b>H</b> 55Y4	90	B144C
	95	RR <b>H</b> 55Y5	115	B144A
	25	35	RR <b>A</b> 56Y2	45
50		RR <b>H</b> 56Y3	90	B144C
70		RR <b>H</b> 56Y4	90	B144C
95		RR <b>H</b> 56Y5	115	B144A
32	50	RR <b>H</b> 58Y3	90	B144C
	70	RR <b>H</b> 58Y4	90	B144C
	95	RR <b>H</b> 58Y5	115	B144A

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)



## CABLE TO REBAR

X-connection horizontal cable to horizontal rebar.

- Rebar material characteristics and location of weld must be considered when selecting connections to rebar.
- Concentric stranded copper cable is listed.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

		Article No.	Part No.
Handle Clamps	for C Price Key Moulds	161000	L160
	for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or Flint Ignitor		165738	PLUSCU T320
Packing Material	One required for each connection - see tables below		

## SUGGESTED TOOLS

Cable Cleaning Brush		165030	T313
Slag Removal Spade			
	#65 w/m & smaller	182125	B136A
	#90 w/m & larger	182130	B136B
Mould Cleaning Brush		165260	T394
File		165260	T329
Torch Head		140160	T111


## RD

REBAR SIZE Diam (mm)	CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>	PACKING MATERIAL
12	25	RDC <b>5</b> 2Y1	65	B141A
	35	RDC <b>5</b> 2Y2	90	B141A
	50	RDM <b>5</b> 2Y3	115	B141A
	70	RDM <b>5</b> 2Y4	115	B141A
	95	RDM <b>5</b> 2Y5	150	B141A
16	25	RDC <b>5</b> 3Y1	65	B141A
	35	RDC <b>5</b> 3Y2	90	B141A
	50	RDM <b>5</b> 3Y3	115	B141A
	70	RDM <b>5</b> 3Y4	115	B141A
	95	RDM <b>5</b> 3Y5	150	B141A

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

REBAR SIZE Diam (mm)	CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>	PACKING MATERIAL
22	35	RD <b>H</b> 55Y2	90	B144C
	50	RD <b>H</b> 55Y3	115	B144C
	70	RD <b>H</b> 55Y4	115	B144C
	95	RD <b>H</b> 55Y5	150	B144A
25	35	RD <b>H</b> 56Y2	90	B144C
	50	RD <b>H</b> 56Y3	115	B144C
	70	RD <b>H</b> 56Y4	115	B144C
	95	RD <b>H</b> 56Y5	150	B144A
32	50	RD <b>H</b> 58Y3	115	B144C
	70	RD <b>H</b> 58Y4	115	B144C
	95	RD <b>H</b> 58Y5	150	B144A

<sup>1</sup> For CADWELD PLUS add suffix "PLUSF20" (refer page 8)



## CABLE / BUSBAR TO REBAR

Horizontal tee - tap of cable or busbar to vertical rebar.

- Rebar material characteristics and location of weld must be considered when selecting connections to rebar.
- Concentric stranded copper cable is listed.
- **Bold letter** in mould part number is the price key.

## REQUIRED TOOLS

		Article No.	Part No.
Handle Clamps	for C&E Price Key Moulds	161000	L160
	for D Price Key Moulds	161020	L159
CADWELD PLUS Control Unit or		165738	PLUSCU
Flint Ignitor		165000	T320
Packing Material	One required for each v connection - see tables below		

## SUGGESTED TOOLS

Cable Cleaning Brush	165030	T313
Slag Removal Spade		
#65 w/m & smaller	182125	B136A
#90 w/m & larger	182130	B136B
Mould Cleaning Brush	165260	T394
File	165260	T329
Torch Head	140160	T111

## RJ

REBAR SIZE Diam (mm)	CABLE SIZE (sq mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>	PACKING MATERIAL
12	25	RJ <b>C</b> 52Y1	65	B140A
	35	RJ <b>C</b> 52Y2	65	B140A
	50	RJ <b>C</b> 52Y3	115	B140A
	70	RJ <b>C</b> 52Y4	115	B140A
	95	RJ <b>C</b> 52Y5	150	B140A
16	25	RJ <b>C</b> 53Y1	65	B140A
	35	RJ <b>C</b> 53Y2	65	B140A
	50	RJ <b>C</b> 53Y3	115	B140A
	70	RJ <b>C</b> 53Y4	115	B140A
	95	RJ <b>C</b> 53Y5	150	B140A
22	35	RJ <b>E</b> 55Y2	65	B144E
	50	RJ <b>E</b> 55Y3	115	B144B
	70	RJ <b>E</b> 55Y4	115	B144B
	95	RJ <b>E</b> 55Y5	150	B144B
	25	35	RJ <b>E</b> 93Y2	65
50		RJ <b>E</b> 93Y3	115	B144B
70		RJ <b>E</b> 93Y4	115	B144B
95		RJ <b>E</b> 93Y5	150	B144B
32		50	RJ <b>E</b> 58Y3	115
	70	RJ <b>E</b> 58Y4	115	B144B
	95	RJ <b>E</b> 58Y5	150	B144E


REBAR SIZE Diam (mm)	BUSBAR (mm)	MOULD PART NO.	WELDING MATERIAL <sup>1</sup>	PACKING MATERIAL
12	3 x 25	RJ <b>C</b> 52CAJ	200	B140A
16		RJ <b>C</b> 53CAJ	200	B140A
22		RJ <b>E</b> 55CAJ	250	B144B
25		RJ <b>E</b> 56CAJ	250	B144B
32		RJ <b>E</b> 58CAJ	250	B144B

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)

Note: All welds to rebar requiring larger than 150 g of welding material will be sold only after review by Pentair.

<sup>1</sup>For CADWELD PLUS add suffix "PLUSF20" (refer page 8)


# CADWELD Cast Ground Plates




## CADWELD CAST GROUND PLATES

CADWELD ground plates used in concrete structures offer convenient ground system connection points. These ground points are used for equipment, machinery and structure grounding after completion of the concrete work.


The castings are made from a copper alloy ... CADWELD ground plate connections result in current carrying capacity equal to that of the conductor or stud and cannot loosen or corrode.



B162-2Q With stud to suit moulds for conductor 4/0 AWG (120 mm<sup>2</sup>)



B164-2Q With stud to suit moulds for conductor 4/0 AWG (120 mm<sup>2</sup>)



DB12A (Article No. 166150) complete with M12 Stud


## CAUTION:

Use only CADWELD cast ground plates. Other similar plates may be available that do not meet the strength requirements necessary. They may crack or break during installation.

Use a CADWELD Type TA or Type SS mould when connecting the CADWELD cast ground plate to the ground conductor. The cast ground plate stud size noted above fits the mould opening for a cable of the same size.

**Example:** Tee connection of 120 mm<sup>2</sup> cable to B164-2Q (4/0 AWG stud size), use mould TACY62Q.  
Splice connection of 120 mm<sup>2</sup> cable to B164-2Q, use mould SSC-2QY6.

# Aircraft Grounding Receptacles



## B-165 and B-165R

The B-165 and B-165R Grounding Receptacles are copper alloy castings intended for use in static grounding systems of aircraft refueling areas. They are easily connected to the grounding system conductor and/or ground rods with CADWELD connections. Designed for simple installation flush with the paved surface. The attachment point (19.05mm ball) is an integral part of the casting on the B-165 and is removable on the B-165R.


### RECEPTACLE B-165 and B-165R

Depth A, Grade Level to Support. 114 mm

Diameter C, at Grade Level 70 mm

### SPECIAL NOTE

ERICO Aircraft Static Grounding Clamp B2617A can be used to connect to B-166 and B-167



## B-166 and B-167

The B-166 and B-167 Combination Tie-down and Static Grounding Receptacles are copper alloy castings. They are easily connected to the grounding system conductor with CADWELD connections. Designed for simple installation flush with the paved surface. The attachment bar (19.05 mm diameter on the B-166 and 38.1 mm on the B-167) is an integral part of the casting.

### RECEPTACLE

**B-166 B-167**

Depth A, Grade Level to Support 159 185


















Diameter B, Maximum Ring Size 121 165














Diameter C, at Grade Level 98 121

For assemblies using B-166 and B-167, contact ERICO.

# Other Cable to Cable Connections










The connections shown below are for use only where connections shown in this catalog are not suitable.












NAME	TYPE	EASE	SPLIT
<b>Parallel dead end</b>	PJ		1 V
	PK		2 *
	PM		3 V
	PN		3 V
<b>Parallel Tap</b>	PH		3 V
	PA		2 *
	PB		3 V
	PC		1 V
	PD		3 V
	PG		1 V
	<b>Splice</b>	PP	
PQ			3 V
PR			2 V
SC			1 *
SD			3 V
SE			3 V
SV			3 V

NAME	TYPE	EASE	SPLIT	
<b>Tee</b>	TC		3 V	
	TD		3 *	
	TE		3 *	
	TF		3 V	
	TL		3 V	
	TV		3 V	
<b>X vertical (horizontal cable uncut)</b>	XC		3 V	
	<b>X vertical (vertical cable uncut)</b>	XD		3 V
		XF		3 *
	<b>X vertical (neither cable cut)</b>	XG		3 *
<b>X - 45° tap</b>	YC		3 V	
	YD		3 V	
	YE		3 V	

# Other Cable to Ground Rods or Other Connections

The connections shown below are for use only where connections shown in this catalog are not suitable.















NAME	TYPE	EASE	SPLIT
Parallel tap	GQ 	3	V
	GS 	1	V
Parallel thru	DQ 	1	V
	GP 	3	V
	GW 	1	V
Splice	GD 	3	V
	GE 	1	V
	GF 	1	V
	GV 	1	V










NAME	TYPE	EASE	SPLIT	
Tee	GG 	1	*	
	GH 	3	V	
	GJ 	1	*	
	GK 	3	V	
	GM 	2	V	
	GN 	2	V	
	GX 	3	V	
	NB 	4	*	
	NC 	1	V	
	ND 	1	V	
	Y - 45° tap	VW 	2	V



# Other Cable to Steel or Cast Iron Connections


















The connections shown below are for use only where connections shown in this catalog are not suitable.














NAME	TYPE	EASE	SPLIT
<b>Tap cast iron</b>	VH 	1	V
	VJ 	1	V
	VK 	1	V
	VR 	1	V
<b>Tap steel</b>	HF 	1	*
	HG 	2	*
	VA 	1	V
	VC 	1	V
	VE 	2	V
	VL 	1	V
	<b>Thru cast iron</b>	HE 	1
<b>Thru steel</b>	HJ 	2	*
	HK 	1	V
	VX 	2	V

NAME	TYPE	EASE	SPLIT
<b>Pipe</b>	HB 	1	*
	VN 	1	*
<b>Other connections to steel</b>	HC 	1	*
	HT 	1	V
	VF 	1	V
	VB 	2	V
	VG 	1	V
	VT 	1	
	VV 	1	V

# Other Cable to Busbar or Lug Connections

















The connections shown below are for use only where connections shown in this catalog are not suitable.













NAME	TYPE	EASE	SPLIT
EII	DN 	2	V
	LX 	2	*
	LY 	3	*
	MA 	2	*
	MB 	3	*
	MC 	3	*
	MD 	3	*
	ME 	2	*
	MF 	3	*
	MG 	2	V
	Lug	PL 	1
Parallel tap	LV 	1	V
Parallel thru	LW 	1	V
Splice	DM 	2	*
	DS 	2	*
	LB 	1	V
	LC 	3	V

NAME	TYPE	EASE	SPLIT	
Splice	LD 	3	V	
	LF 	3	*	
	LG 	3	V	
	LH 	3	*	
	LK 	2	V	
	LL 	1	V	
	LM 	1	V	
	LN 	4	*	
	LP 	2	*	
	LS 	2	*	
	LT 	2	*	
	LQ 	2	V	
	Tee	LR 	2	*

















# Other Busbar to Busbar Connections




















The connections shown below are for use only where connections shown in this catalog are not suitable.

NAME	TYPE	EASE	SPLIT	
<b>Button-weld</b>	TW		1	*
	TX		1	V
<b>EII</b>	DJ		4	V
	EN		2	*
	EQ		4	V
	ER		2	*
	ES		3	*
	ET		2	V
	EV		3	*
	EP		1	V
<b>Parallel tap</b>	BJ		2	V
<b>Splice</b>	BC		3	V
	BD		3	*
	BF		2	*
	BG		2	*
	BH		4	V

NAME	TYPE	EASE	SPLIT	
<b>Tee</b>	BK		2	*
	BL		3	*
	BN		3	*
	BR		2	V
	BS		2	V
	BT		4	*
	BV		3	*
	DE		3	V
	EE		3	V
	<b>X</b>	EA		4
EC			4	*
ED			4	V









# Other Busbar Connections / Other Rebar Connections









NAME	TYPE	EASE	SPLIT
Tap	BX		3 V
	BY		3 V
	CA		3 V
	CB		2 V
	CJ		2 V
	DC		3 *
	DD		3 V
	DF		2 V
	HL		1 V
	HM		1 V
	HN		1 *
Thru	CD		3 V
	CK		2 V
	CF		1 V
	CC		1 V
	CH		1 V

NAME	TYPE	EASE	SPLIT
EII	DT		2 V
Parallel tap	DR		2 V
	RV		2 V
Parallel thru	RT		2 V
	RW		2 V
Splice	RE		2 V
	RF		2 V
	RG		1 V
	SF		2 V
	SR		1 V
	Tee	RH	
RK			1 *
RL			2 V
RM			2 V
RN			2 V
RP			2 V
RQ			2 V
X		XJ	
	RC		1 V

# Cable to Copper Tube Connections



The connections shown below are for use only where connections shown in this catalog are not suitable.




NAME	TYPE	EASE	SPLIT
<b>EII</b>	DP		1 *
	MV		2 V
	MW		3 V
	MX		2 V
	MY		3 V
<b>Splice</b>	MH		1 V
	MJ		3 V
	MK		3 V

NAME	TYPE	EASE	SPLIT
<b>Tee</b>	ML		1 *
	MM		3 *
	MP		3 *
	MQ		3 *
	MR		3 *
	MS		3 *
	MT		3 *
	NA		1 *

# Busbar to Ground Rods Connections


The connections shown below are for use only where connections shown in this catalog are not suitable.


NAME	TYPE	EASE	SPLIT
<b>EII</b>	CL		1 V
<b>Tee</b>	CM		3 V

NAME	TYPE	EASE	SPLIT
<b>Splice</b>	CS		3 V
<b>Tee</b>	CQ		3 V
	CR		1 V

## Copper Tube to Ground Rods Connections






The connections shown below are for use only where connections shown in this catalog are not suitable.







NAME	TYPE	EASE	SPLIT
EII	FT 	1	V

NAME	TYPE	EASE	SPLIT
Tee	FV 	1	V

## Copper Tube to Copper Tube Connections




The connections shown below are for use only where connections shown in this catalog are not suitable.



NAME	TYPE	EASE	SPLIT
EII	FK 	1	*
	FL 	3	V
	FM 	2	V
Splice	FD1 	V	
	FE 	3	V

NAME	TYPE	EASE	SPLIT
Tee	FH 	3	V
	FF 	1	*
	FG 	2	V
	FH 	3	V
	FJ 	3	V
X	XT 	4	*

## Copper Tube to Busbar or Lugs Connections


The connections shown below are for use only where connections shown in this catalog are not suitable.

NAME	TYPE	EASE	SPLIT
Splice	FN 	1	*
	FP 	1	V
Tee	EW 	2	V

NAME	TYPE	EASE	SPLIT
Tee	FR 	2	*
	FS 	1	V

## ADAPTING MOULDS TO FIT CONDUCTORS

Cables smaller than indicated on mould tag can be welded by using either Wrap Sleeve or Adapter Sleeves.




### CADWELD Wrap Sleeve B140A

CADWELD Wrap Sleeve is wrapped around the cable until the diameter is about the same as the cable opening in the mould.


### CADWELD Adapter Sleeves

CADWELD Adapter Sleeves are used to adapt a limited range of smaller size cables to a larger size CADWELD Mould.



CABLE SIZE Concentric Strand	Adapter Sleeve Part No.	Use in Mould for Stranded
4	B-133-1H	10
10	B-133-1L	25
16	B-112	25
16	B-133-1V	35
25*	B-133-1Y	35
35	B-133-2C	50
35	B-133-2G	70
50	B-133-2L	70
70	B-133-2Q	95

\*Substitute for 7/2.14 only



### Packing

Packing consists of either preformed ceramic packing or sometimes B140A or B141A copper wrap shim. Packing is required on all rebar connections.



T403


### CADWELD Mould Sealer

T403 CADWELD Mould Sealer is ideal for sealing hot or cold moulds to retard leakage from large stranded conductors. It is required on certain moulds such as Types HA, HB, HC, VG and VN. It prolongs useful mould life when the cable opening becomes worn.

It is available in a convenient 0.9 kg package.

# Material, Tools and Accessories


## CABLE AND WORK SURFACE PREPARATION



T313


### Cable Cleaning Brushes

Two types of brushes are available to aid in removing oxides and cleaning copper surfaces. T313 Card Cloth Brush with short stiff bristles is generally preferred for cleaning concentric conductors and busbars, which are not heavily oxidized.



T314


T314 Cable Cleaning Brush cleans any conductor and is especially useful for coarse or very dirty conductors. The brushes can be rotated to provide new cleaning bristles and are replaceable.



B265

### Cable Clamp B265


The B265 Cable clamp should be used with hard drawn copper cable, Copperweld® DSA conductor or any cable under tension. Use of the clamp aids in preventing cable movement and prolongs mould life.



T321

### Rasp


T321 rasp is used to remove rust from any steel surface or galvanizing from hot dipped galvanized steel to expose the bare steel for welding. The curved blade makes it an efficient tool for flat surfaces. T321A Replacement blades are also available.



T111

### Surefire® Torch Head


T111 Self igniting propane torch head. Squeeze the control knob for an instant flame. Release and it's out. No flame adjusting. The burn tip remains cool during normal use. Operates on its side or upside down. Can withstand 60 MPH winds without flareout. Fits all standard 14 and 16 oz. propane cylinders.



T372A

### Galvanizing Touch-Up

Easy to use galvanizing paint in a spray can is used to touch up heat affected areas on galvanized steel surfaces after welding. The damage to the galvanizing is often minimal so the repair is often cosmetic. T372A galvanizing compound available in 12 ounce aerosol can.




T319

### Galvanizing Bar

T319 Galvanizing Bar is used to repair a galvanized surface that has been damaged by welding or drilling. This is a low temperature, self-fluxing material. Often there is sufficient heat after making the CADWELD Connection to melt the bar or a small torch may be used.



## MOULD CARE AND USE




T394

### Mould Cleaning Brush

Mould cleaning brush T394 is very useful for removing slag from moulds – especially vertically split moulds.

### Slag Removal Spades

Slag Removal Spades are useful for removing the slag after making a CADWELD Connection – especially useful with horizontally split moulds.




B136A  
B136B

Slag Spade Part No.	Use With Mould Price	Using Welding Material Size
B-136-A B-136-B	A,C, & R C,D,F & R	#65 & Smaller #90 & Larger

### Disks

Each time a weld is made, a new disk is required. The disk sits on the bottom of the crucible. Its purpose is to hold the welding material until the reaction takes place. The slag produced by the reaction rises to the surface and the molten copper settles to the bottom of the crucible where it melts the disk and melts through the conductors to produce a permanent molecular bond.




Disks are available in three sizes:

B117A used in moulds using #15 thru #32 welding material (3/4" diameter).

B117B used in moulds using #45 thru #115 welding material (1" diameter).

B117C used in moulds using #150 thru #500 welding material (1-1/2" diameter).

**Disks are included with Welding Material.**




T328D

### Disk Kit

A disk container (T328) which includes 20 of each of the three sizes of steel disks is available for your convenience. Kit P/N T328D.


## MOULD FASTENING AND MOUNTING

### CADWELD Handle Clamps



Handle Clamps such as the one shown are required for most moulds. Specialized frames with handles are used on some moulds. Flint ignitors are included with all Handle Clamps. The following Handle Clamps are most widely used.

1. L160 for all moulds having a "C", "E", "Q", or "R" mould price key.  
(3" wide moulds)
2. L159 for all moulds having a "D", "F", "J" or "Z" mould price key.  
(4" wide moulds)



### Vertical Surface Mould Support


A CADWELD mould can be securely held to a vertical "H" column or angle by using the Vertical Surface Mould Support. It is easily attached to an existing L159 or L160 Handle Clamp. For use with Types VB, VG, VN, and VS moulds, fits steel up to 1" thick, for Type VF mould, 3/4" thick.

B134: For use with L160 E-Z CHANGE Handle Clamp

B135: For use with L159 E-Z CHANGE Handle Clamp

### Chain Support Handle Clamps

A CADWELD mould can be securely held to a pipe using the clamp assembly consisting of a modified L159 or L160 Handle Clamp with built-in pipe attachment.




Clamp Part No.	Fits Mould Price	For Following Connection Types	Pipe
B159V	D & F	VS,VF,VB, & VV	Vertical
B160V	C & R	VS,VF,VB, & VV	Vertical
B159VT	D & F	VT	Vertical
B160VT	C & R	VT	Vertical
B159H	D & F	HA,HS,HC, & HT	Horizontal
B160H	C & R	HA,HS,HC, & HT	Horizontal

The above clamps are equipped with 500 mm length of chain which will fit up to 100 mm pipes. Extra 500 mm length of chain, B158, is available to fit up to 250 mm pipes.

# Material, Tools and Accessories


## Magnetic Handle Clamps

A CADWELD mould can be securely held to a large flat or slightly curved vertical surface using the Handle Clamp with Magnetic Support. Used on vertically split moulds.



Clamp Part No.	Fits Mould Price Key	Minimum Width Required*
B396	C & R Price Key	8"
B159M	D & F Price Key	10-1/2"
B399AM	T Price Key	6"
B399BM	P & N Price Key	7"

\*Width will vary slightly depending upon the type of connection being made.



## Fence Fabric Attachment Assembly

An easy to use, labor saving, Fence Fabric Attachment Assembly fastens to your existing L159 or L160 Handle Clamp to firmly hold your mould to the fence post after the fence fabric has been attached. Ideal for retrofit jobs.

Fence Fabric Attachment Part No.	Fits Handles
B827A	L160, L159

# Material, Tools and Accessories


## GROUND ROD SPECIALTY TOOLS



### ERICO Ground Rod Drivers

Product #	Description
EGRD58	5' Driver body with insert for up to 5/8" ground rods
EGRD58I*	Replacement insert for 5/8" ground rods
EGRD34	5' Driver body with insert for up to 3/4" ground rods
EGRD34I*	Replacement insert for 3/4" ground rods

\*Both 5/8" and 3/4" inserts fit standard body of EGRD58 or EGRD34.




### Ground Rod Driving Sleeves\*\*

Use a CADWELD ground rod driving sleeve to prevent mushrooming top of ground rod.

Ground Rod Size	Part No.
1/2" Copper Bonded or Steel Rod	B137-14
5/8" Copper Bonded (.563" diameter)	B137-16
5/8" Steel (.625" diameter)	B137-31
3/4" Copper Bonded (.682" diameter)	B137-18
3/4" Steel (.750" diameter)	B137-33
1" Copper Bonded (.914" diameter)	B137-22
1" Steel (1.00" diameter)	B137-37

\*\* For plain (unthreaded) ground rods only.




B120

### Ground Rod Splice Clamp

The B120 Ground Rod Splice Clamp must be used to support the upper rod and provide a method of correctly positioning the rods and mould while splicing the rods. (Type HDGB and GB Connection).


## OTHER TOOLS



T320

### Flint Ignitors

T320 CADWELD Flint Ignitors are used to ignite the starting material when making a CADWELD Connection. An ignitor is included with each Handle Clamp or frame. T320A Replacement Flints are also available.




B321-30

### Flint Ignitor Extension


B321-30 Flint Ignitor Extension attaches to the T320 Flint Ignitor and allows the installer to be about 30" from the mould. Ideal for such operations where the mould is in a narrow trench and the installer is at ground level.

# Material, Tools and Accessories



## Ceramic Blanket

The woven Ceramic Blanket (Part T306) can be used to hold a hot mould or keep the work surface free of slag when cleaning the mould.




**File**  
T329




**Pliers**  
T304

## Screwdriver



T305



XLB974-B2


## Welding Tray

The Welding Tray (Part No. XLB974-B2) can contain a spill of molten welding material. It is for personnel safety. Recommended when working overhead or over expensive equipment.

## TOOL KITS

### Tool Box T396

A tool box is highly recommended to carry tools, moulds, welding material and a propane torch.



T396

Tool Box T396 is included in Tool Kit T315A

### Tool Kit T315A


Other Tool Kits can be made for your particular requirements.




T328D




T320




B136A




T329




T393



T314




T313




T305




T304



T394



T378L




T321

## TOOL TRAY

### Tool Tray Only: T331

Ideal for carrying one or two moulds, welding material, propane torch and tools.



T331

Tool Tray T331 is not included in Tool Kit T315A

# Reference Material

## OTHER SPECIALIZED APPLICATION CATALOGS, APPLICATIONS, BULLETINS AND TECHNICAL INFORMATION

**A1L ERICO STATIC GROUNDING CONNECTIONS**

**A4G CADWELD SUBSTATION GROUNDING**

Numerous applications and guidelines for grounding electrical supply station (substations).

**A7D CADWELD INSTALLERS AND INSPECTORS GUIDE**

A guide for installation and inspection of CADWELD exothermically welded connections.

**A9E CADWELD CONTRACTOR TIPS**


Ideal for contractors – How to save time and make the installation easy.

**CA1A CADWELD CATHODIC PROTECTION CONNECTIONS CATALOG**

---

## TRAINING VIDEOS

**E469D CADWELD/CADWELD PLUS CD**



Product #	Description
G157LT99	Practical Guide to Electrical Grounding

**WARNING**

Pentair products shall be installed and used only as indicated in Pentair's product instruction sheets and training materials. Instruction sheets are available at [www.ericopentair.com](http://www.ericopentair.com) and from your Pentair customer service representative. Improper installation, misuse, misapplication or other failure to completely follow Pentair's instructions and warnings may cause product malfunction, property damage, serious bodily injury and/or death, and void your warranty.






www.erico.pentair.com



**AUSTRALIA**  
Phone 1-800-263-508  
Fax 1-800-423-091



**CHINA**  
Phone +86-21-3430-4878  
Fax +86-21-5831-8177



**HUNGARY**  
Phone 06-800-16538  
Fax +39-0244-386-107



**NORWAY**  
Phone 800-100-73  
Fax 800-100-66



**SWITZERLAND**  
Phone 0800-55-86-97  
Fax 0800-55-96-15



**BELGIUM**  
Phone 0800-757-48  
Fax 0800-757-60



**DENMARK**  
Phone 808-89-372  
Fax 808-89-373



**INDONESIA**  
Phone +62-21-575-0941  
Fax +62-21-575-0942



**POLAND**  
Phone +48-71-349-04-60  
Fax +48-71-349-04-61



**THAILAND**  
Phone +66-2-267-5776  
Fax +66-2-636-6988



**BRAZIL**  
Phone +55-11-3623-4333  
Fax +55-11-3621-4066



**FRANCE**  
Phone 0-800-901-793  
Fax 0-800-902-024



**ITALY**  
Phone 800-870-938  
Fax 800-873-935



**SINGAPORE**  
Phone +65-6-268-3433  
Fax +65-6-268-1389



**UNITED ARAB EMIRATES**  
Phone +971-4-881-7250  
Fax +971-4-881-7270



**CANADA**  
Phone +1-800-677-9089  
Fax +1-800-677-8131



**GERMANY**  
Phone 0-800-189-0272  
Fax 0-800-189-0274



**MEXICO**  
Phone +52-55-5260-5991  
Fax +52-55-5260-3310



**SPAIN**  
Phone 900-993-154  
Fax 900-807-333



**UNITED KINGDOM**  
Phone 0808-2344-670  
Fax 0808-2344-676




**CHILE**  
Phone +56-2-370-2908  
Fax +56-2-369-5657



**HONG KONG**  
Phone +852-2764-8808  
Fax +852-2764-4486



**NETHERLANDS**  
Phone 0800-0200-135  
Fax 0800-0200-136



**SWEDEN**  
Phone 020-790-908  
Fax 020-798-964



**UNITED STATES**  
Phone 1-800-753-9221  
Fax +1-440-248-0723

AutoCad is a registered trademark of Autodesk, Inc.  
Copperweld is a registered trademark of Copperweld Corporation  
IEEE is a registered trademark of The Institute of Electrical and Electronics Engineers, Inc.  
NEC is a registered trademark of National Fire Protection Association, Inc.  
NEMA is a registered trademark of National Electrical Manufacturers Association  
Surefire is a registered trademark of Newell-Rubbermade Company

© 2009, 2015 Pentair All Rights Reserved  
Pentair, CADDY, CADWELD, CRITEC, ERICO, ERIFLEX, ERITECH and LENTON are owned by Pentair or its global affiliates. All other trademarks are the property of their respective owners. Pentair reserves the right to change specifications without prior notice.